

All Outlets Testing Above Threshold

| School | Sample ID | Test Number | Lead PPM | Sample Date/Time | Outlet Type (Sink/Fountain, etc.) | Used for Drinking/Cooking (Y/N/Potentially) | Notes | Remediation |
|------------------|---------------|---------------|------------------|------------------|--------------------------------------|---|-----------------|--------------------|
| Fisher | CVFS1A | 161007059-001 | 0.022 | 10/17/2016 20:48 | Sink | Y | Handles Removed | Replaced/Retesting |
| | CVFS1C | 161007059-003 | 0.024 | 10/17/2016 23:44 | Left Sink | Y | Handles Removed | |
| | CVFS2 | 161007059-007 | 0.023 | 10/18/2016 0:05 | Sink | Y | Sign | |
| | CVFS0B | 161007059-008 | 0.018 | 10/18/2016 0:11 | Sink | Y | Handles Removed | |
| | CVFS4B | 161007059-013 | 0.04 | 10/19/2016 17:12 | Sink | Y | Handles Removed | |
| | CVFS4C | 161007059-014 | 0.042 | 10/19/2016 17:17 | Work Room Sink | Y | Handles Removed | |
| | CVF135S | 161007059-017 | 0.046 | 10/19/2016 17:33 | Sink | Y | Handles Removed | |
| | CVF132S | 161007059-019 | 0.016 | 10/19/2016 17:56 | Sink | Y | Handles Removed | |
| | CVF131S | 161007059-020 | 0.02 | 10/19/2016 18:02 | Sink | Y | Handles Removed | |
| | CVF129S | 161007059-022 | 0.045 | 10/19/2016 18:33 | Sink | Y | Handles Removed | |
| | CVFS6 | 161007059-024 | 0.03 | 10/18/2016 12:37 | Sink | Y | Handles Removed | |
| | CVF125S | 161007059-025 | 0.022 | 10/18/2016 12:42 | Sink | Y | Handles Removed | |
| | CVFS7 | 161007059-026 | 0.016 | 10/18/2016 12:48 | Sink | Y | Handles Removed | |
| | CVF111SB | 161007059-091 | 0.027 | 10/20/2016 10:14 | Sink | Y | Sign | |
| | CVFS13 | 161007059-096 | 0.065 | 10/20/2016 11:19 | Sink | P | Handles Removed | |
| CVF106SA | 161007059-104 | 0.017 | 10/20/2016 12:15 | Sink | Y | Handles Removed | | |
| Barringer | CVBS4D | 161007049-078 | 0.019 | 10/14/2016 18:57 | Sink | Y | Handles Removed | Replace & Retest |
| Jarvis | CVJ111SA | 161007061-025 | 0.016 | 10/14/2016 10:51 | Sink | P | Sign | |
| | CVJS24F | 161007061-082 | 0.028 | 10/17/2016 20:08 | Sink | P | Handles Removed | |
| Remington | CVR1101C | 161024004-093 | 0.022 | 10/31/2016 16:37 | Sink | Y | Handles Removed | |

All Outlets Testing Above Threshold

| School | Sample ID | Test Number | Lead PPM | Sample Date/Time | Outlet Type (Sink/Fountain, etc.) | Used for Drinking/Cooking (Y/N/Potentially) | Notes | Remediation |
|--------|-----------|---------------|--------------|------------------|--------------------------------------|---|-----------------|-------------|
| | CVR1201B | 161024004-013 | 0.037 | 10/28/2016 11:47 | Bathroom Sink | P | Sign | |
| | CVR1203B | 161024004-083 | 0.05 | 10/29/2016 2:08 | Bathroom Sink | P | Sign | |
| | CVR1203B | 161024004-083 | 0.045 | 10/29/2016 1:59 | Bathroom Sink | P | Duplicate | |
| | CVR1205A | 161024004-084 | 0.192 | 10/31/2016 14:38 | Sink | P | Handles Removed | |
| | CVR1205B | 161024004-085 | 0.057 | 10/31/2016 15:03 | Bathroom Sink | P | Sign | |
| | CVR1208A | 161024004-002 | 0.017 | 10/27/2016 21:34 | Sink | Y | Handles Removed | |
| | CVR1208B | 161024004-003 | 0.046 | 10/27/2016 21:48 | Sink | Y | Handles Removed | |
| | CVR1208B | 161024004-003 | 0.043 | 10/27/2016 21:40 | Sink | Y | Duplicate | |
| | CVR1208C | 161024004-004 | 0.039 | 10/27/2016 22:02 | Sink | Y | Handles Removed | |
| | CVR1208D | 161024004-005 | 0.031 | 10/27/2016 22:07 | Kettle | Y | Handles Removed | |
| | CVR1208S | 161024004-007 | 0.091 | 10/28/2016 10:20 | Sink | P | Handles Removed | |
| | CVR1209S | 161024004-089 | 0.047 | 10/31/2016 16:14 | Slop Sink | P | Handles Removed | |
| | CVR1212S | 161024004-001 | 0.251 | 10/28/2016 10:14 | Slop Sink | P | Handles Removed | |
| | CVR1215BS | 161024004-011 | 0.065 | 10/28/2016 10:39 | Sink | Y | Handles Removed | |
| | CVR1215F | 161024004-008 | 0.209 | 10/28/2016 10:03 | Fountain | Y | Not in Use | |
| | CVR1215S | 161024004-009 | 0.216 | 10/28/2016 10:08 | Sink | Y | Handles Removed | |
| | CVR1303C | 161024004-111 | 0.046 | 10/31/2016 19:35 | Mop Filler | N | Handles Removed | |
| | CVR1402 | 161024004-076 | 0.082 | 10/29/2016 1:00 | Bathroom Sink | P | Sign | |
| | CVR1404B | 161024004-079 | 0.032 | 10/29/2016 1:36 | Bathroom Sink | P | Sign | |
| | CVR1405 | 161024004-077 | 0.049 | 10/29/2016 1:14 | Sink | P | Handles Removed | |

All Outlets Testing Above Threshold

| School | Sample ID | Test Number | Lead PPM | Sample Date/Time | Outlet Type (Sink/Fountain, etc.) | Used for Drinking/Cooking (Y/N/Potentially) | Notes | Remediation |
|--------|-----------|---------------|--------------|------------------|--------------------------------------|---|-----------------|-------------|
| | CVR1407A | 161024004-060 | 0.029 | 10/28/2016 21:42 | Sink | P | Handles Removed | |
| | CVR1407B | 161024004-061 | 0.213 | 10/28/2016 22:12 | Bathroom Sink | P | Sign | |
| | CVR1407B | 161024004-061 | 0.195 | 10/28/2016 22:04 | Bathroom Sink | P | Duplicate | |
| | CVR1408A | 161024004-056 | 0.061 | 10/28/2016 21:11 | Sink | P | | |
| | CVR1408A | 161024004-056 | 0.054 | 10/28/2016 21:03 | Sink | P | Duplicate | |
| | CVR1408B | 161024004-057 | 0.047 | 10/28/2016 21:25 | Sink | P | Handles Removed | |
| | CVR1410B | 161024004-059 | 0.02 | 10/28/2016 21:36 | Bathroom Sink | P | Sign | |
| | CVR1411B | 161024004-030 | 0.051 | 10/28/2016 14:39 | Bathroom Sink | P | Sign | |
| | CVR1414B | 161024004-068 | 0.02 | 10/28/2016 23:35 | Bathroom Sink | Y | Sign | |
| | CVR2402A | 161024004-107 | 0.029 | 10/31/2016 19:12 | Sink | P | Handles Removed | |
| | CVR2410S | 161024004-098 | 0.037 | 10/31/2016 17:25 | Slop Sink | P | Handles Removed | |
| | CVR2414 | 161024004-025 | 0.017 | 10/28/2016 14:03 | Sink | Y | Handles Removed | |
| | CVR2421S | 161024004-036 | 0.056 | 10/28/2016 15:54 | Slop Sink | P | Handles Removed | |
| | CVR2421S | 161024004-036 | 0.05 | 10/28/2016 17:58 | Slop Sink | P | Duplicate | |
| | CVR2422 | 161024004-017 | 0.025 | 10/28/2016 12:32 | Sink | Y | Handles Removed | |
| | CVRS1 | 161024004-086 | 0.422 | 10/31/2016 15:26 | Sink | P | Handles Removed | |
| | CVRS2 | 161024004-087 | 0.371 | 10/31/2016 15:48 | Bathroom Sink | P | Sign | |
| | CVRS3B | 161024004-034 | 0.115 | 10/28/2016 15:34 | Center Boys Restroom Sink | P | Sign | |
| | CVRS4A | 161024004-037 | 0.021 | 10/28/2016 18:15 | Left Girls Restroom Sink | P | Sign | |
| | CVRS6C | 161024004-028 | 0.019 | 10/28/2016 14:19 | Right Girls Restroom Sink | P | Sign | |

All Outlets Testing Above Threshold

| School | Sample ID | Test Number | Lead PPM | Sample Date/Time | Outlet Type (Sink/Fountain, etc.) | Used for Drinking/Cooking (Y/N/Potentially) | Notes | Remediation |
|-----------|---------------|---------------|------------------|-------------------------|--------------------------------------|---|-----------------|-------------|
| | CVRS7A | 161024004-099 | 0.016 | 10/31/2016 17:31 | Left Boys Restroom Sink | P | Sign | |
| | CVRS7C | 161024004-101 | 0.142 | 10/31/2016 18:10 | Right Boys Restroom Sink | P | Sign | |
| CVA | CVA2511K | 161107009-071 | 0.712 | 11/23/2016 12:37 | Sink | P | Handles Removed | |
| | CVA2511F | 161107009-066 | 0.384 | 11/22/2016 22:46 | Sink | P | Handles Removed | |
| | CVA2511L | 161107009-072 | 0.289 | 11/23/2016 12:40 | Sink | P | Handles Removed | |
| | CVA2508B | 161107009-084 | 0.282 | 11/23/2016 21:01 | Sink | P | Handles Removed | |
| | CVA2506D | 161107009-101 | 0.205 | 11/24/2016 0:43 | Sink | P | Handles Removed | |
| | CVA2508J | 161107009-092 | 0.192 | 11/23/2016 22:36 | Sink | P | Handles Removed | |
| | CVA2505J | 161107009-129 | 0.191 | 11/24/2016 5:14 | Sink | P | Handles Removed | |
| | CVA2509 | 161107009-074 | 0.176 | 11/25/2016 14:53 | Sink | P | Sign | |
| | CVA1436 | 161107009-031 | 0.168 | 11/22/2016 17:22 | Sink | P | Handles Removed | |
| | CVA1501H | 161107009-012 | 0.123 | 11/17/2016 16:44 | Sink | P | Handles Removed | |
| | CVA1501G | 161107009-011 | 0.118 | 11/17/2016 16:21 | Sink | P | Handles Removed | |
| | CVA2509A | 161107009-073 | 0.117 | 11/23/2016 14:07 | Sink | P | Handles Removed | |
| | CVA1504D | 161107009-025 | 0.111 | 11/22/2016 17:17 | Sink | P | Handles Removed | |
| | CVA1506H | 161107009-015 | 0.111 | 11/17/2016 18:00 | Lab Sink | P | Sign | |
| | CVA2504K | 161107009-121 | 0.107 | 11/24/2016 4:01:51AM | Lab Sink | P | Sign | |
| | CVA2504G | 161107009-117 | 0.096 | 11/24/2016 2:53:04AM | Lab Sink | P | Sign | |
| | CVA1501I | 161107009-013 | 0.091 | 11/17/2016 17:06 | Sink | P | Handles Removed | |
| CVA1502B1 | 161107009-001 | 0.091 | 11/17/2016 14:03 | Prep Room Sink | P | Handles Removed | | |
| CVA2506F | 161107009-103 | 0.085 | 11/24/2016 1:03 | Sink | P | Handles Removed | | |

All Outlets Testing Above Threshold

| School | Sample ID | Test Number | Lead PPM | Sample Date/Time | Outlet Type (Sink/Fountain, etc.) | Used for Drinking/Cooking (Y/N/Potentially) | Notes | Remediation |
|--------|-----------|---------------|--------------|--------------------------|--------------------------------------|---|-----------------|-------------|
| | CVA1051E | 161107009-009 | 0.073 | 11/17/2016 15:42 | Sink | P | Handles Removed | |
| | CVA2505A1 | 161107009-080 | 0.064 | 11/23/2016 20:13 | Sink | P | Sign | |
| | CVA1501J | 161107009-014 | 0.062 | 11/17/2016 17:37 | Sink | P | Handles Removed | |
| | CVA2508A | 161107009-083 | 0.06 | 11/23/2016 20:38 | Sink | P | Handles Removed | |
| | CVA2505G | 161107009-130 | 0.045 | 11/24/2016 5:39 | Sink | P | Handles Removed | |
| | CVA2508L | 161107009-094 | 0.042 | 11/23/2016 22:56 | Sink | P | Handles Removed | |
| | CVA1501C | 161107009-007 | 0.041 | 11/17/2016 15:15 | Sink | P | Handles Removed | |
| | CVA1501F | 161107009-010 | 0.029 | 11/17/2016 15:59 | Sink | P | Handles Removed | |
| | CVA2504N | 161107009-124 | 0.027 | 11/24/2016 4:29 | Lab Sink | P | Sign | |
| | CVA1329SA | 161107007-022 | 0.024 | 11/10/2016 17:14 | Left Sink | P | Sign | |
| | CVA1501A | 161107009-005 | 0.024 | 11/17/2016 14:56 | Sink | P | Handles Removed | |
| | CVA1501B | 161107009-006 | 0.022 | 11/17/2016 15:01 | Sink | P | Handles Removed | |
| | CVA1504A | 161107009-022 | 0.022 | 11/19/2016 23:37 | Sink | P | Handles Removed | |
| | CVA2506A1 | 161107009-110 | 0.022 | 11/24/2016 1:54 | Sink | P | Handles Removed | |
| | CVA1501A1 | 161107009-004 | 0.019 | 11/17/2016 14:20 | Prep Room Sink | P | Sign | |
| | CVA2508E | 161107009-087 | 0.018 | 11/23/2016 21:30 | Sink | P | Handles Removed | |
| | CVA1323SA | 161107007-041 | 0.017 | 11/16/2016 10:47:31AM | Left Sink | P | Handles Removed | |
| | CVA1425 | 161107009-056 | 0.017 | 11/22/2016 21:04 | Slop Sink | N | Sign | |
| | CVA2504H | 161107009-118 | 0.017 | 11/24/2016 3:25 | Lab Sink | P | Sign | |
| | CVA1416B | 161107009-051 | 0.016 | 11/22/2016 20:24 | Middle Sink | P | Sign | |
| | CVA1416C | 161107009-052 | 0.016 | 11/22/2016 20:41 | Right Sink | P | sign | |

All Outlets Testing Above Threshold

| School | Sample ID | Test Number | Lead PPM | Sample Date/Time | Outlet Type (Sink/Fountain, etc.) | Used for Drinking/Cooking (Y/N/Potentially) | Notes | Remediation |
|----------------|-----------|---------------|--------------|------------------|--------------------------------------|---|-----------------|-------------|
| | CVA2511B | 161107009-062 | 0.016 | 11/22/2016 21:50 | Sink | P | Handles Removed | |
| Outdoor | CVLT1 | 170519044-003 | 0.018 | 5/9/2017 | Lower Concession Stand Sink | P | Disconnected | |