

Harry M. Fisher Elementary School Lead Testing Results

Sample ID	Test Number	Lead PPM	Sample Date/Time	Location (Room#, Hallway, etc.)	Outlet Type (Sink/Fountain, etc.)	Used for Drinking/Cooking (Y/N/Potentially)	Notes	Remediation
CVFS1A	161007059-001	0.022	10/17/2016 20:48	Kitchen	Sink	Y	Handles Removed	Replaced/Retesting
CVFS1B	161007059-002	0.004	10/17/2016 23:38	Kitchen	Sink	Y		
CVFS1C	161007059-003	0.024	10/17/2016 23:44	Kitchen	Left Sink	Y	Handles Removed	
CVFS1D	161007059-004	0.006	10/17/2016 23:49	Kitchen	Dish Washer	Y		
CVF159SA	161007059-005	0.006	10/17/2016 23:55	159	Sink	Y		
CVF159SB	161007059-006	0.002	10/18/2016 0:00	159	Sink	Y		
CVFS2	161007059-007	0.023	10/18/2016 0:05	Men/Women's HW by Nurse	Sink	Y	Sign	
CVFS0B	161007059-008	0.018	10/18/2016 0:11	Bathroom	Sink	Y	Handles Removed	
CVFS3A	161007059-009	0.006	10/18/2016 0:16	Nurse	Sink	Y		
CVFS3B	161007059-010	0.007	10/19/2016 16:37	Nurse	Sink	Y		
CVFS3C	161007059-011	0.004	10/19/2016 16:42	Nurse	Sink	Y		
CVFS4A	161007059-012	0.015	10/19/2016 17:01	Office	Bathroom Sink	Y		
CVFS4B	161007059-013	0.04	10/19/2016 17:12	Office	Sink	Y	Handles Removed	
CVFS4C	161007059-014	0.042	10/19/2016 17:17	Office	Work Room Sink	Y	Handles Removed	
CVFS5	161007059-015	0.015	10/19/2016 17:22	Library Work Rm	Sink	Y		
CVFF1	161007059-016	0.001	10/19/2016 17:28	Hallway by Library	Drinking Fountain	Y		
CVF135S	161007059-017	0.046	10/19/2016 17:33	135	Sink	Y	Handles Removed	
CVF133S	161007059-018	0.015	10/19/2016 17:50	133	Sink	Y		
CVF132S	161007059-019	0.016	10/19/2016 17:56	132	Sink	Y	Handles Removed	
CVF131S	161007059-020	0.02	10/19/2016 18:02	131	Sink	Y	Handles Removed	
CVF130S	161007059-021	0.015	10/19/2016 18:27	130	Sink	Y		
CVF129S	161007059-022	0.045	10/19/2016 18:33	129	Sink	Y	Handles Removed	
CVF128S	161007059-023	0.005	10/18/2016 12:31	128	Sink	Y		
CVFS6	161007059-024	0.03	10/18/2016 12:37	Computer Lab	Sink	Y	Handles Removed	
CVF125S	161007059-025	0.022	10/18/2016 12:42	125	Sink	Y	Handles Removed	
CVFS7	161007059-026	0.016	10/18/2016 12:48	124	Sink	Y	Handles Removed	
CVFS8A	161007059-027	0.01	10/18/2016 12:54	Boys/Girls	Slop Sink	P		

Harry M. Fisher Elementary School Lead Testing Results

Sample ID	Test Number	Lead PPM	Sample Date/Time	Location (Room#, Hallway, etc.)	Outlet Type (Sink/Fountain, etc.)	Used for Drinking/Cooking (Y/N/Potentially)	Notes	Remediation
CVFS8B	161007059-028	0.006	10/18/2016 12:59	Boys Bathroom	Sink	P		
CVFS8C	161007059-029	0.004	10/18/2016 13:05	Boys Bathroom	Sink	P		
CVFS8D	161007059-030	0.013	10/18/2016 13:11	Boys Bathroom	Sink	P		
CVFS8E	161007059-031	0.003	10/18/2016 13:33	Girls Bathroom	Sink	P		
CVFS8F	161007059-032	0.007	10/18/2016 13:39	Girls Bathroom	Sink	P		
CVFS8G	161007059-033	0.007	10/18/2016 13:45	Girls Bathroom	Sink	P		
CVF177S	161007059-035	0.005	10/18/2016 13:56	177	Sink	P		
CVFS10A	161007059-036	0.009	10/18/2016 14:02	Hallway by Boys/Girls	Slop Sink	P		
CVFS10B	161007059-037	0.01	10/18/2016 14:08	Boys Bathroom	Sink	P		
CVFS10C	161007059-038	0.008	10/18/2016 14:14	Boys Bathroom	Sink	P		
CVFS10E	161007059-039	0.006	10/18/2016 14:36	Girls Bathroom	Sink	P		
CVFS10F	161007059-040	0.009	10/18/2016 14:41	Girls Bathroom	Sink	P		
CVF179S	161007059-041	0.01	10/18/2016 15:10	179	Sink	Y		
CVF179F	161007059-042	0.01	10/18/2016 15:15	179	Fountain	Y		
CVF181S	161007059-043	0.013	10/18/2016 15:37	181	Sink	Y		
CVF181F	161007059-044	0.01	10/18/2016 15:43	181	Fountain	Y		
CVFS11A	161007059-045	0.011	10/18/2016 15:49	Art 182	Sink	P		
CVFS11B	161007059-046	0.008	10/18/2016 15:55	Art 182	Sink	P		
CVFS11C	161007059-047	0.009	10/18/2016 16:01	Art 182	Fountain	P		
CVF183S	161007059-048	0.009	10/18/2016 16:06	183	Sink	Y		
CVF183F	161007059-049	0.005	10/18/2016 16:12	183	Fountain	Y		
CVF177F	161007059-050	0.005	10/18/2016 16:17	177	Fountain	Y		
CVF185SA	161007059-051	0.006	10/18/2016 16:39	185	Sink	Y		
CVF185SB	161007059-052	0.004	10/18/2016 16:45	185	Sink	Y		
CVF185F	161007059-053	0.003	10/18/2016 16:50	185	Fountain	Y		
CVF184SA	161007059-054	0.003	10/18/2016 16:56	184	Sink	Y		
CVF184SB	161007059-055	0.003	10/18/2016 17:01	184	Sink	Y		

Harry M. Fisher Elementary School Lead Testing Results

Sample ID	Test Number	Lead PPM	Sample Date/Time	Location (Room#, Hallway, etc.)	Outlet Type (Sink/Fountain, etc.)	Used for Drinking/Cooking (Y/N/Potentially)	Notes	Remediation
CVF184F	161007059-056	0.001	10/18/2016 17:07	184	Fountain	Y		
CVF207SA	161007059-057	0.006	10/18/2016 17:12	207	Sink	Y		
CVF207SB	161007059-058	0.003	10/18/2016 17:18	207	Sink	Y		
CVF207F	161007059-059	0.001	10/19/2016 18:50	207	Fountain	Y		
CVFS14	161007059-060	0.002	10/20/2016 16:20	Slop by 207	Slop Sink	P		
CVF206SA	161007059-061	0.006	10/19/2016 22:25	206	Sink	Y		
CVF206SB	161007059-062	0.001	10/19/2016 22:31	206	Sink	Y		
CVF206F	161007059-063	0.002	10/19/2016 22:36	206	Fountain	Y		
CVF205SA	161007059-064	0.004	10/19/2016 22:52	205	Sink	Y		
CVF205SB	161007059-065	0.001	10/19/2016 22:58	205	Sink	Y		
CVF205F	161007059-066	0.001	10/19/2016 23:04	205	Fountain	Y		
CVF204SA	161007059-067	0.008	10/19/2016 23:26	204	Sink	Y		
CVF204SB	161007059-068	0.002	10/19/2016 23:53	204	Sink	Y		
CVF204F	161007059-069	0.004	10/19/2016 23:59	204	Fountain	Y		
CVF212SB	161007059-070	0.002	10/20/2016 0:04	212	Sink	Y		
CVF212F	161007059-071	0.001	10/20/2016 0:10	212	Fountain	Y		
CVF211SA	161007059-072	0.004	10/20/2016 0:15	211	Sink	Y		
CVF211SB	161007059-073	0.002	10/20/2016 0:21	211	Sink	Y		
CVF211F	161007059-074	0.001	10/20/2016 0:27	211	Fountain	Y		
CVF210SA	161007059-075	0.007	10/20/2016 0:44	210	Sink	Y		
CVF210SB	161007059-076	0.001	10/20/2016 0:49	210	Sink	Y		
CVF210F	161007059-077	0.001	10/20/2016 0:55	210	Fountain	Y		
CVF209SA	161007059-078	0.002	10/20/2016 1:01	209	Sink	Y		
CVF209SB	161007059-079	0.002	10/20/2016 1:07	209	Sink	Y		
CVF209F	161007059-080	0.002	10/20/2016 1:13	209	Fountain	Y		
CVF208SA	161007059-081	0.005	10/20/2016 1:18	208	Sink	Y		
CVF208SB	161007059-082	0.002	10/20/2016 1:24	208	Sink	Y		

Harry M. Fisher Elementary School Lead Testing Results

Sample ID	Test Number	Lead PPM	Sample Date/Time	Location (Room#, Hallway, etc.)	Outlet Type (Sink/Fountain, etc.)	Used for Drinking/Cooking (Y/N/Potentially)	Notes	Remediation
CVF208F	161007059-083	< 0.001	10/20/2016 1:41	208	Fountain	Y		
CVF108F	161007059-084	< 0.001	10/20/2016 1:47	108	Fountain	Y		
CVF109SA	161007059-085	0.002	10/20/2016 1:53	109	Sink	Y		
CVF109SB	161007059-086	0.005	10/20/2016 1:59	109	Sink	Y		
CVF109F	161007059-087	< 0.001	10/20/2016 9:42	109	Fountain	Y		
CVF110SA	161007059-088	0.002	10/20/2016 9:47	110	Sink	Y		
CVF110F	161007059-089	< 0.001	10/20/2016 9:53	110	Fountain	Y		
CVF111SA	161007059-090	0.002	10/20/2016 9:58	111	Sink	Y		
CVF111SB	161007059-091	0.027	10/20/2016 10:14	111	Sink	Y	Sign	
CVF111F	161007059-092	0.003	10/20/2016 10:39	111	Fountain	Y		
CVF112SA	161007059-093	0.003	10/20/2016 10:44	112	Sink	Y		
CVF112SB	161007059-094	0.006	10/20/2016 10:49	112	Sink	Y		
CVF112F	161007059-095	< 0.001	10/20/2016 10:55	112	Fountain	Y		
CVFS13	161007059-096	0.065	10/20/2016 11:19	PHYS Office	Sink	P	Handles Removed	
CVF212SA	161007059-097	0.008	10/20/2016 11:25	212	Sink	Y		
CVF105SA	161007059-098	0.01	10/20/2016 11:30	105	Sink	Y		
CVF105SB	161007059-099	0.003	10/20/2016 11:36	105	Fountain	Y		
CVF105F	161007059-100	0.002	10/20/2016 11:41	105	Sink	Y		
CVF104SA	161007059-101	0.01	10/20/2016 11:47	104	Sink	Y		
CVF104SB	161007059-102	0.004	10/20/2016 11:52	104	Sink	Y		
CVF104F	161007059-103	0.002	10/20/2016 12:09	104	Fountain	Y		
CVF106SA	161007059-104	0.017	10/20/2016 12:15	106	Sink	Y	Handles Removed	
CVF106SB	161007059-105	0.008	10/20/2016 12:20	106	Sink	Y		
CVF106F	161007059-106	0.004	10/20/2016 12:26	106	Fountain	Y		
CVF107SA	161007059-107	0.012	10/20/2016 12:47	107	Sink	Y		
CVF107SB	161007059-108	0.002	10/20/2016 13:04	107	Sink	Y		
CVF107F	161007059-109	0.001	10/20/2016 13:22	107	Fountain	Y		

Harry M. Fisher Elementary School Lead Testing Results

Sample ID	Test Number	Lead PPM	Sample Date/Time	Location (Room#, Hallway, etc.)	Outlet Type (Sink/Fountain, etc.)	Used for Drinking/Cooking (Y/N/Potentially)	Notes	Remediation
CVF108SA	161007059-110	0.002	10/20/2016 13:27	108	Sink	Y		
CVF108SB	161007059-111	0.007	10/20/2016 13:33	108	Sink	Y		
CVF110SB				110	Sink	Y	DOESN'T WORK	
CVFS9A				Hallway by Front Entrance	Drinking Fountain	P		
CVFS9B				Hallway by Front Entrance	Drinking Fountain	P		