

Gregory B. Jarvis Middle School Lead Testing Results

Sample ID	Test Number	Lead PPM	Sample Date/Time	Location (Room#, Hallway, etc.)	Outlet Type (Sink/Fountain, etc.)	Used for Drinking/Cooking (Y/N/Potentially)	Notes	Remediation
CVJS33E	161007061-001	0.002	10/13/2016 17:40	Women's Bathroom	Sink	P		
CVJF9	161007061-002	0.002	10/13/2016 17:46	Restroom by 102	Sink	P		
CVJS34	161007061-003	0.007	10/13/2016 18:02	Custodial by 302	Slop Sink	P		
CVJ825	161007061-004	0.005	10/13/2016 18:08	Women's Library Bathroom	Sink	P		
CVJF02	161007061-005	0.002	10/13/2016 18:14	By 105	Fountain	P		
CVJS1A	161007061-006	0.008	10/13/2016 18:36	Maintenance Bathroom	Slop Sink	P		
CVJS1B	161007061-007	0.003	10/13/2016 18:42	Maintenance Bathroom	Sink	P		
CVJFM	161007061-008	< 0.001	10/13/2016 19:18	Faculty Restroom	Sink	P		
CVJS2A	161007061-009	0.003	10/13/2016 19:46	Library Office	Sink	N		
CVJ1A	161007061-010	0.002	10/13/2016 19:51	1	Sink	P		
CVJB1B	161007061-011	0.002	10/13/2016 19:57	Men's Library Bathroom	Sink	P		
CVJB1C	161007061-012	0.002	10/13/2016 20:03	Men's Library Bathroom	Sink	P		
CVJB2A	161007061-013	0.003	10/13/2016 20:08	By 002	Fountain	Y		
CVJB2B	161007061-014	0.003	10/13/2016 20:14	Men's Locker Rm by Hallway	High Drinking Fountain	Y		
CVJB2C	161007061-015	0.003	10/13/2016 20:20	Men's Locker Rm by Hallway	Low Drinking Fountain	Y		
CVJF1A	161007061-016	< 0.001	10/14/2016 9:40	By 102	Fountain	Y		
CVJF1B	161007061-017	< 0.001	10/14/2016 9:57	By 202	Fountain	Y		
CVJS3A	161007061-018	0.003	10/14/2016 10:13	Men's Locker Rm	Sink	P		
CVJS3B	161007061-019	0.006	10/14/2016 10:19	Men's Locker Rm Coach's	Sink	P		
CVJS4A	161007061-020	0.01	10/14/2016 10:24	Girls Locker Rm	Sink	P		
CVJS4B	161007061-021	0.012	10/14/2016 10:29	Girls Locker Rm Coach's	Sink	P		
CVJS5	161007061-022	0.01	10/14/2016 10:35	By 107	Slop Sink	P		
CVJF2	161007061-023	0.004	10/14/2016 10:40	By 205	Fountain	Y		
CVJ111S	161007061-024	0.006	10/14/2016 10:45	111	Sink	P		
CVJ111SA	161007061-025	0.016	10/14/2016 10:51	Bathroom	Sink	P	Sign	
CVJ111SB	161007061-026	0.004	10/14/2016 11:13	Bathroom	Sink	P		
CVJ104SA	161007061-027	0.004	10/14/2016 11:18	104	Sink	Y		
CVJ104SB	161007061-028	0.001	10/14/2016 11:23	104	Sink	Y		
CVJ104SC	161007061-029	0.004	10/14/2016 11:29	104	Sink	Y		
CVJ104SD	161007061-030	0.005	10/14/2016 11:34	104	Sink	Y		
CVJ104SE	161007061-031	0.004	10/14/2016 11:39	104	Sink	Y		

Gregory B. Jarvis Middle School Lead Testing Results

Sample ID	Test Number	Lead PPM	Sample Date/Time	Location (Room#, Hallway, etc.)	Outlet Type (Sink/Fountain, etc.)	Used for Drinking/Cooking (Y/N/Potentially)	Notes	Remediation
CVJ104SF	161007061-032	0.002	10/14/2016 11:45	104	Sink	Y		
CVJ104SG	161007061-033	0.002	10/14/2016 12:14	104	Sink	Y		
CVJS7A	161007061-034	0.002	10/14/2016 12:35	Women's by Vault	Sink	P		
CVJS7B	161007061-035	0.006	10/14/2016 12:41	Men's by Vault	Sink	P		
CVJS7C	161007061-036	0.003	10/14/2016 13:05	Men's By Vault	Sink	P		
CVJF3	161007061-037	0.001	10/14/2016 13:11	By 207	Fountain	Y		
CVJ826A	161007061-038	0.004	10/14/2016 13:44	Women's Library Bathroom	Sink	P		
CVJ826B	161007061-039	0.005	10/14/2016 13:50	Women's Library Bathroom	Sink	P		
CVJ826C	161007061-040	0.005	10/14/2016 13:55	Men's Library Bathroom	Sink	P		
CVJS8	161007061-041	0.004	10/14/2016 14:01	Custodial by 102	Slop Sink	P		
CVJS9A	161007061-042	0.003	10/14/2016 14:07	Art	Left Sink	P		
CVJS9B	161007061-043	0.003	10/14/2016 14:12	Art	Right Sink	P		
CVJS9C	161007061-044	0.003	10/14/2016 14:18	Art	Left Sink	P		
CVJS9D	161007061-045	0.004	10/14/2016 14:24	Art	Right Sink	P		
CVJS10	161007061-046	0.002	10/14/2016 14:47	Kitchen Tray Return	Sink	P		
CVJS11	161007061-047	0.002	10/14/2016 14:52	Kitchen Tray Return	Sink	P		
CVJ101S	161007061-048	0.002	10/14/2016 14:58	101	Sink	Y		
CVJS12	161007061-049	0.003	10/14/2016 15:04	Kitchen	Sink	P		
CVJS13A	161007061-050	0.005	10/14/2016 15:09	Kitchen	Combo Sink	P		
CVJS13B	161007061-051	0.005	10/14/2016 15:15	Kitchen	Sink	P		
CVJS13C	161007061-052	0.009	10/14/2016 15:26	Kitchen	Sink	P		
CVJS13D	161007061-053	0.014	10/14/2016 18:46	Kitchen	Slop Sink	P		
CVJS13E	161007061-054	0.014	10/14/2016 18:51	Faculty Rm Kitchen	Sink	P		
CVJS13F	161007061-055	0.01	10/14/2016 18:57	Kitchen	Sink	P		
CVJS13G	161007061-056	0.008	10/14/2016 19:31	Kitchen	Sink	P		
CVJS13H	161007061-057	0.005	10/14/2016 19:37	Instrumental Music	Sink	P		
CVJS13I	161007061-058	0.012	10/14/2016 19:42	By 203 Men/Women	Garage Sink	N		
CVJS13J	161007061-059	0.01	10/14/2016 19:48	Men's	Garage Sink	N		
CVJK1A	161007061-060	0.012	10/14/2016 19:54	Food Service Locker Rm	Sink	P		
CVJS14	161007061-061	0.005	10/14/2016 20:00	Custodial by Aud.	Slop Sink	P		
CVJF4	161007061-062	0.006	10/14/2016 20:06	By 317	Fountain	N		

Gregory B. Jarvis Middle School Lead Testing Results

Sample ID	Test Number	Lead PPM	Sample Date/Time	Location (Room#, Hallway, etc.)	Outlet Type (Sink/Fountain, etc.)	Used for Drinking/Cooking (Y/N/Potentially)	Notes	Remediation
CVJS15	161007061-063	0.002	10/14/2016 20:40	Main Office	Sink	Y		
CVJ15A	161007061-064	0.001	10/14/2016 20:45	2	Sink	P		
CVJF5	161007061-065	0.002	10/14/2016 20:51	Hallway 308	Fountain	Y		
CVJS16	161007061-066	0.002	10/14/2016 20:57	Main Office	Sink	Y		
CVJS17A	161007061-067	0.008	10/14/2016 21:03	Nurse	Sink	Y		
CVJS17B	161007061-068	0.005	10/14/2016 21:08	Nurse	Sink	Y		
CVJ18A	161007061-069	0.003	10/14/2016 21:30	1	Sink	P		
CVJS18B	161007061-070	0.005	10/14/2016 21:36	Women by 207	Garg Sink	N		
CVJ19	161007061-071	0.009	10/14/2016 21:41	1	Sink	P		
CVJF6	161007061-072	0.002	10/14/2016 21:47	Hallway by 304	Fountain	Y		
CVJS20	161007061-073	0.01	10/14/2016 21:52	Men by 207	Garg Sink	N		
CVJF7	161007061-074	0.003	10/14/2016 21:57	Maintenance Rm	Fountain	Y		
CVJS22	161007061-075	0.004	10/14/2016 22:03	Men by 317	Garg Sink	Y		
CVJS23	161007061-076	0.004	10/17/2016 19:07	Women by 320	Garg Sink	Y		
CVJS24A	161007061-077	0.003	10/17/2016 19:13	316	Sink	P		
CVJS24B	161007061-078	0.003	10/17/2016 19:19	316	Sink	P		
CVJS24C	161007061-079	0.004	10/17/2016 19:25	316	Sink	P		
CVJS24D	161007061-080	0.003	10/17/2016 19:47	316	Sink	P		
CVJS24E	161007061-081	0.005	10/17/2016 20:03	316	Sink	P		
CVJS24F	161007061-082	0.028	10/17/2016 20:08	316	Sink	P	Handles Removed	
CVJS24G	161007061-083	0.01	10/17/2016 20:14	316	Sink	P		
CVJS25A	161007061-084	0.012	10/17/2016 20:19	315	Sink	P		
CVJS25B	161007061-085	0.01	10/17/2016 20:24	315	Sink	P		
CVJS25C	161007061-086	0.003	10/17/2016 20:47	315	Sink	P		
CVJS25D	161007061-087	0.004	10/17/2016 20:52	315	Sink	P		
CVJS25E	161007061-088	0.005	10/17/2016 20:58	315	Sink	P		
CVJS25F	161007061-089	0.007	10/17/2016 21:03	315	Sink	P		
CVJS25G	161007061-090	0.005	10/17/2016 21:09	315	Sink	P		
CVJS26A	161007061-091	0.003	10/17/2016 21:15	314	Sink	P		
CVJS26B	161007061-092	0.005	10/17/2016 21:20	314	Sink	P		
CVJS26C	161007061-093	0.004	10/17/2016 21:26	314	Sink	P		

Gregory B. Jarvis Middle School Lead Testing Results

Sample ID	Test Number	Lead PPM	Sample Date/Time	Location (Room#, Hallway, etc.)	Outlet Type (Sink/Fountain, etc.)	Used for Drinking/Cooking (Y/N/Potentially)	Notes	Remediation
CVJS26D	161007061-094	0.002	10/17/2016 21:48	314	Sink	P		
CVJS26E	161007061-095	0.005	10/17/2016 21:53	314	Sink	P		
CVJS27A	161007061-096	0.006	10/17/2016 21:59	313	Sink	P		
CVJS27B	161007061-097	< 0.001	10/18/2016 9:56	313	Sink	P		
CVJS27C	161007061-098	0.002	10/18/2016 10:02	313	Sink	P		
CVJS27D	161007061-099	< 0.001	10/18/2016 10:24	313	Sink	P		
CVJS27E	161007061-100	< 0.001	10/18/2016 10:29	313	Sink	P		
CVJS27F	161007061-101	< 0.001	10/18/2016 10:35	313	Sink	P		
CVJS27G	161007061-102	0.003	10/18/2016 10:40	313	Sink	P		
CVJS27H	161007061-103	0.001	10/18/2016 10:46	313	Sink	P		
CVJS28	161007061-104	0.003	10/18/2016 10:51	Therapy Rm by 313	Sink	P		
CVJS29A	161007061-105	0.003	10/18/2016 10:57	312	Sink	P		
CVJS29B	161007061-106	0.003	10/18/2016 11:02	312	Sink	P		
CVJS29C	161007061-107	0.003	10/18/2016 11:24	312	Sink	P		
CVJS30	161007061-108	0.005	10/18/2016 11:30	310	Sink	P		
CVJS31	161007061-109	0.002	10/18/2016 11:35	Custodial by 310	Slop Sink	P		
CVJS32	161007061-110	0.003	10/18/2016 11:41	Rest Rm by 310	Sink	P		
CVJF8	161007061-111	0.003	10/18/2016 11:46	Kitchen	Kettle	Y		
CVJS33A	161007061-112	0.003	10/18/2016 11:52	Men's Bathroom	Sink	P		
CVJS33B	161007061-113	0.006	10/18/2016 11:57	Men's Bathroom	Sink	P		
CVJS33C	161007061-114	0.005	10/18/2012 12:03	Men's Bathroom	Sink	P		
CVJS33D	161007061-115	0.003	10/18/2016 12:25	Women's Bathroom	Sink	P		
CVJS33F				Women's Bathroom	Sink	P	DOESN'T WORK	